

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20254147
Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Inspection - Commercial	Mitchell Schwarz	Failed	Monday, September 29, 2025

Corrective Action Required:

1	Misc	-install bonding jumper from EGC bus bar to the service grounded bus bar -Enclose conductors and SE cable inside raceways -Secure raceways per code -Fix the service in place, not on wheels please
---	------	--

Comments: