

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251166

Address: 655 SE BRADFREE ST, LEES SUMMIT, MO 64063657 SE BRADFREE ST, LEES SUMMIT, MO 64063659
SE BRADFREE ST, LEES SUMMIT, MO 64063653 SE BRADFREE ST, LEES SUMMIT, MO
64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mitchell Schwarz	Failed	Monday, September 29, 2025

Corrective Action Required:

1 Misc

NOT A COMPLETE INSPECTION, TRUSSES NOT INSPECTED

DO NOT INSULATE

-Provide city stamped truss plans on site for inspection

Throughout

-will check GB bracing at time of drywall

653

-missing stud in stud pack per plans front bedroom

655

657

659

Comments: