

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253406
Address: 1039 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Shawn Hoffman	Failed	Tuesday, September 30, 2025

Corrective Action Required:

1	Misc	Plumbing approved - remove all organic material (forms, wood, trash) and call in re- inspection DO Not Pour Floor
---	------	--

Comments: