

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245048
Address: 2739 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Failed	Tuesday, September 30, 2025

Corrective Action Required:

2	Misc	2739 SW Heartland Rd <ul style="list-style-type: none">- Handrail on deck stairs, must provide a continuous non interrupted handrail for entire length of stairway on one side- Outlet lower back patio to left of sliding door not gfci protected- Outlet for washer not functioning- Out at refrigerator end of island not functioning- Pay outstanding fees- Final sidewalk inspection needed
---	------	---

Comments: