

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251690
Address: 860 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	Robb Popp	Partial	Wednesday, October 01, 2025

Corrective Action Required:

1	Misc	Light test on (3) of (3) grease ducts ok 1st layer at (3) of (3) 2nd layer of wrap at (2) of (3) ducts approved
---	------	---

Comments: