

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRDEM20252027
Address: 1208 SW JEFFERSON ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Demo	Shawn Hoffman	Partial	Thursday, October 02, 2025

Corrective Action Required:

1	Miscellaneous Correction	- On May 08, 2025, Water Operations performed the Water service line abandonment for the address of 1208 SW Jefferson St. This abandonment was in response to the customer performing a demolition of the structure on the property.
---	--------------------------	--

The sewer service has been temporarily abandoned at the back of the curb as agreed upon between Water Utilities and the Oldham Village Developer (David Olson). The service lateral will attempt to be reused for the future structure, or if unable to do so it is required be properly abandoned at the main before any C of O is issued for that site.

Comments: