

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246285

Address: 1333 SW WINTHROP TER, LEES SUMMIT, MO 640811331 SW WINTHROP TER, LEES SUMMIT, MO
64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Partial	Thursday, September 11, 2025

Corrective Action Required:

1	Misc	7-21-25 Dustin A, Sidewalk has broken panels and a panel that was replaced without a pre pour inspection. 9-11-25 Dustin A, sw panels that failed due to cracks and being poured without a inspection have been removed, formed and compacted as well as the rest of sw. Slopes are in compliance. Approved to pour
---	------	--

Comments: