

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252025
Address: 1432 SE SILO ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, October 06, 2025

Corrective Action Required:

1	Misc	-obtain issued lawn irrigation permit -sod -splash blocks and sump pump discharge to extend 36" from foundation -guard rail required at front stoop -open junction boxes at front -provide proper illumination for address -fireblock top of garage door to ceiling -place attic access cover in garage -guard rail at deck shall not have openings greater than 4" -open junction bock above deck -Outside outlet north side of house, not working
---	------	---

Comments: