

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246287

Address: 1344 SW WINTHROP TER, LEES SUMMIT, MO 640811342 SW WINTHROP TER, LEES SUMMIT, MO
64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Partial	Monday, October 06, 2025

Informational:

1 Misc

10-6-25 Dustin A, Sw has been poured to city specs and slopes are in compliance. Will hold off on passing until final grade is done due to water valve is low with the grading going on. Valve lid will need to be flush with final grade

Comments: