

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246287
Address: 1344 SW WINTHROP TER, LEES SUMMIT, MO 640811342 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Dustin Agcopra	Partial	Monday, October 06, 2025

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	7-17-25 Dustin A, Silt fence is down curb line and street needs cleaned. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 7-21-25 Dustin A, Silt fence is still down 8-4-25 Dustin A, All corrections had been made, esc must be maintained throughout project.
---	----------------------------	--

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	10-2-25 Dustin A, Silt fence is down on lot and streets and curb needs to be cleaned. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 10-6-25 Dustin A, Corrections have been made,
---	----------------------------	---

Comments: