

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20253506
Address: 2201 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Failed	Tuesday, October 07, 2025

Corrective Action Required:

1	Misc	Fire partition pre-rock-OK
		All fire-rated walls-1st layer OK
		Wall B.5/1-3, 2nd layer OK on north side
		**Correction: screw 2nd layer to bottom track every 8" oc

Comments: