

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252810

Address: 1224 SE WINDBREAK DR, LEES SUMMIT, MO 640811222 SE WINDBREAK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, October 07, 2025

Corrective Action Required:

1	Misc	THROUGHOUT
---	------	------------

-fireplace furr out wall will need to be spaced out to allow for gypsum board on party wall
-repair roof sheathing within 4' of party wall and repair holes

1222

-move radon pipe hangers so it will not interfere with party wall

1224

Comments: