

Job Name : The Discovery at Discovery - Lot 5
Address : 19200 NE Discovery Ave. - Lee's summit, Mo

Date : 8/26/2025
Sprinkler Contractor : Goal Fire Protection, LLC

Area Info :

Calculation Summary :

<u>Area #1</u> : Unit, 3 rd Floor
<u>Area #2</u> : Unit, 3 rd Floor
<u>Area #3</u> : Unit, 2nd Floor
<u>Area #4</u> : Unit, 2 nd Floor
<u>Area #5</u> : Shell Space

Water Supply :

Flow Test :

Date : 6-3-2025
Static : 115 PSI
Residual : 70 PSI
Flow : 1501 GPM
Elevation : Same as 1st F.F.
Location of Flow Test : Looped City Main
Source of Flow Test : Goal Fire Protection

Notes :



WATER FLOW TEST REPORT



Property Name: Discovery Park

City, State: Lee's Summit, MO

Conducted by: Wyatt Porter

HYDRANT # & LOCATION Ramp

DATE: 6/3/2025

WITNESS BY N/A

DAY OR WEEK:

TIME OF DAY: 8:30

WEATHER: Cloudy

WATER SUPPLIED BY:

PURPOSE OF TEST: Annual Inspection & Flow Rate

DATA

FLOW HYDRANT(S)

	A1	A2	A3
SIZE OPENING:	2.5	0	0
COEFFICIENT:	0.9	0	0
PITOT READING:	80	0	0
GPM:	1501	0	0

TOTAL FLOW DURING TEST: 1501 GPM

STATIC READING: 115 PSI


RESIDUAL: 70 PSI

RESULTS: AT 20 PSI RESIDUAL 2247 GPM

AT 0 PSI 2491 GPM

ESTIMATED CONSUMPTION: 1501 GAL.

REMARKS: Coefficient Per NFPA 291 (Smooth & Rounded Hydrant Butt = 0.90) (Square & Sharp Hydrant Butt = 0.80)
(Square Butt Projecting Into Hydrant Barrell 0.70) (Smooth & Rounded Hydrant Butt **FM GLOBAL** = 0.80)



Job Name : **The Discovery at Discovery - Lot 5**
Address : **1900 NE Discovery Ave. - Lee's summit, Mo**

Date : **8/26/2025**
Sprinkler Contractor : **Goal Fire Protection, LLC**

Area Info : **Area #1 - Unit, 3rd Floor**
Area Design : **Per NFPA-13R, 2016**

Design Criteria :
Gpm for head: **17.0** Psi for head: **15.0**
Total Sprinklers Operating: **2** Sprinkler K Factor: **4.4**
Outside Hose Allowance: **100**

Calculation Summary :

GPM Required : 46.47	PSI Required : 82.25	@ Base of Riser
GPM Required : 146.47	PSI Required : 82.69	@ Connection to City Main

Area Safety Margin: **31.6 PSI 28 %**


Notes :

Water Supply Curve

The Village at Discovery - Lot 5 Area #1

City Water Supply:
C1 - Static Pressure : 115
C2 - Residual Pressure: 70
C2 - Residual Flow : 1501

Demand:
D1 - Elevation : 15.158
D2 - System Flow : 46.471
D2 - System Pressure : 82.696
Hose (Demand) : 100
D3 - System Demand : 146.471
Safety Margin : 31.697



Fittings Used Summary

The Village at Discovery - Lot 5 Area #1

Fitting Legend																					
Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90' Ell	0	4	5	6	7	9	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Branch Tee	0	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zca	Colt C200 Horz Butt	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

The Village at Discovery - Lot 5 Area #1

Page 3
Date

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	115.0	70	1501.0	114.392	146.47	82.696

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>	
H101	35.0	4.4	28.38	23.44	0.1	170
101A	35.0		28.86			
101B	26.0	4.4	34.06	23.03	0.1	230
H102	35.0		27.4			
102A	35.0	4.4	27.87	23.03	0.1	230
102B	26.0		33.02			
303	26.0	4.4	33.59	23.03	0.1	230
A2	26.0		34.76			
A3	26.0	4.4	34.9	23.03	0.1	230
A4	26.0		41.95			
A5	26.0	4.4	42.37	23.03	0.1	230
A6	26.0		43.15			
A7	26.0	4.4	43.61	23.03	0.1	230
A8	26.0		58.21			
A9	25.5	4.4	59.46	23.03	0.1	230
A10	13.85		66.59			
TOR2	13.85	4.4	66.82	23.03	0.1	230
BOR2	3.5		74.74			
UG	1.0	4.4	82.25	23.03	0.1	230
HOSE	0.0		82.7			
TEST	0.0	4.4	82.7	100.0		

Final Calculations : Hazen-Williams

Page 4
Date

The Village at Discovery - Lot 5 Area #1

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H101 to 101A	35 35	4.40	23.44 23.44	1 1.101	N	5.0	0.300 5.000 5.300	150 0.0913	28.379 0.0 0.484		Vel = 7.90	
101A to 101B	35 26		0.0 23.44	1 1.101	N	5.0	9.250 5.000 14.250	150 0.0912	28.863 3.898 1.300		Vel = 7.90	
101B to A2	26 26		0.0 23.44	1 1.101	O	5.0	2.650 5.000 7.650	150 0.0912	34.061 0.0 0.698		Vel = 7.90	
A2			0.0 23.44						34.759		K Factor = 3.98	
H102 to 102A	35 35	4.40	23.03 23.03	1 1.101	N	5.0	0.300 5.000 5.300	150 0.0883	27.400 0.0 0.468		Vel = 7.76	
102A to 102B	35 26		0.0 23.03	1 1.101	N	5.0	9.250 5.000 14.250	150 0.0884	27.868 3.898 1.259		Vel = 7.76	
102B to 303	26 26		0.0 23.03	1 1.101	O	5.0	1.400 5.000 6.400	150 0.0883	33.025 0.0 0.565		Vel = 7.76	
303 to A3	26 26		0.0 23.03	1 1.101	O	5.0	9.850 5.000 14.850	150 0.0884	33.590 0.0 1.312		Vel = 7.76	
A3			0.0 23.03						34.902		K Factor = 3.90	
A2 to A3	26 26		23.44 23.44	1.25 1.394			4.950 4.950	150 0.0289	34.759 0.0 0.143		Vel = 4.93	
A3 to A4	26 26		23.03 46.47	1.25 1.394			68.650 68.650	150 0.1026	34.902 0.0 7.043		Vel = 9.77	
A4 to A5	26 26		0.0 46.47	1.25 1.394			4.100 4.100	150 0.1027	41.945 0.0 0.421		Vel = 9.77	
A5 to A6	26 26		0.0 46.47	1.25 1.394			7.650 7.650	150 0.1025	42.366 0.0 0.784		Vel = 9.77	
A6 to A7	26 26		0.0 46.47	1.25 1.394			4.450 4.450	150 0.1027	43.150 0.0 0.457		Vel = 9.77	
A7 to A8	26 26		0.0 46.47	1.25 1.394	N O	6.0 6.0	130.300 12.000 142.300	150 0.1026	43.607 0.0 14.599		Vel = 9.77	
A8 to A9	26 25.500		0.0 46.47	1.25 1.394	N	6.0	4.100 6.000 10.100	150 0.1025	58.206 0.217 1.035		Vel = 9.77	
A9 to A10	25.500 13.850		0.0 46.47	1.25 1.442	E	3.716	12.150 3.716 15.866	120 0.1315	59.458 5.046 2.086		Vel = 9.13	

Final Calculations : Hazen-Williams

Page 5
Date

The Village at Discovery - Lot 5 Area #1

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
A10			0.0 46.47						66.590		K Factor = 5.69	
A10 to TOR2	13.850 13.850		46.47 46.47	2 2.157			12.330 12.330	120 0.0185	66.590 0.0 0.228		Vel = 4.08	
TOR2			0.0 46.47						66.818		K Factor = 5.68	
TOR2 to BOR2	13.850 3.500		46.47 46.47	2 2.157	B E Fsp	7.384 6.153 0.0	10.350 13.537 23.887	120 0.0185	66.818 7.483 0.441		** Fixed Loss = 3 Vel = 4.08	
BOR2 to UG	3.500 1		0.0 46.47	4 4.26	E Zca	13.167 0.0	6.500 13.167 19.667	120 0.0007	74.742 7.499 0.014		** Fixed Loss = 6.417 Vel = 1.05	
UG to HOSE	1 0		0.0 46.47	6 6.16	G E T	4.304 20.084 43.037	20.000 67.425 87.425	140 0.0001	82.255 0.433 0.007		Vel = 0.50	
HOSE to TEST	0 0	H100	100.00 146.47	6 6.16			1.000 1.000	140 0.0010	82.695 0.0 0.001		Vel = 1.58	
TEST			0.0 146.47						82.696		K Factor = 16.11	

Job Name : **The Discovery at Discovery - Lot 5**
Address : **1900 NE Discovery Ave. - Lee's summit, Mo**

Date : **8/26/2025**
Sprinkler Contractor : **Goal Fire Protection, LLC**

Area Info : **Area #2 - Unit, 3rd Floor**
Area Design : **Per NFPA-13R, 2016**

Design Criteria :
Gpm for head: **17.0** Psi for head: **15.0**
Total Sprinklers Operating: **3** Sprinkler K Factor: **4.4**
Outside Hose Allowance: **100**

Calculation Summary :

GPM Required : 70.58	PSI Required : 100.66	@ Base of Riser
GPM Required : 170.58	PSI Required : 101.11	@ Connection to City Main

Area Safety Margin: **13.0** PSI **12** %

Notes :

Water Supply Curve

The Village at Discovery - Lot 5 Area #2


Page 1
Date

City Water Supply:

C1 - Static Pressure : 115
C2 - Residual Pressure: 70
C2 - Residual Flow : 1501

Demand:

D1 - Elevation : 15.158
D2 - System Flow : 70.583
D2 - System Pressure : 101.113
Hose (Demand) : 100
D3 - System Demand : 170.583
Safety Margin : 13.081



Fittings Used Summary

The Village at Discovery - Lot 5 Area #2

Fitting Legend																					
Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90' Ell	0	4	5	6	7	9	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Branch Tee	0	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zca	Colt C200 Horz Butt	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

The Village at Discovery - Lot 5 Area #2

Page 3
Date

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	115.0	70	1501.0	114.195	170.58	101.113

NODE ANALYSIS

Node Tag	Elevation	Node Type	Pressure at Node	Discharge at Node	Notes		
H201	35.0	4.4	30.02	24.11	0.1	170	
201A	35.0		30.53				
201B	26.0		35.8				
201C	26.0		36.44				
H203	35.0	4.4	28.39	23.44	0.1	230	
203A	35.0		28.87				
203B	26.0		34.07				
H202	35.0	4.4	27.4	23.03	0.1	230	
202A	35.0		27.87				
202B	26.0		33.02				
H402	26.0		33.95				
402	26.0		34.77				
A4	26.0		37.94				
A5	26.0		38.07				
A6	26.0		38.3				
A7	26.0		39.29				
A8	26.0		70.92				
A9	25.5		73.38				
A10	13.85		82.95				
TOR2	13.85		83.44				
BOR2	3.5		91.88				
UG	1.0		100.66				
HOSE	0.0		101.11				100.0
TEST	0.0		101.11				

Final Calculations : Hazen-Williams

Page 4
Date

The Village at Discovery - Lot 5 Area #2

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H201 to 201A	35 35	4.40	24.11 24.11	1 1.101	O	5.0	0.300 5.000 5.300	150	30.018 0.0			
								0.0962	0.510	Vel =	8.12	
201A to 201B	35 26		0.0 24.11	1 1.101	N	5.0	9.250 5.000 14.250	150	30.528 3.898			
								0.0961	1.369	Vel =	8.12	
201B to 201C	26 26		0.0 24.11	1 1.101	O	5.0	1.750 5.000 6.750	150	35.795 0.0			
								0.0961	0.649	Vel =	8.12	
201C to A4	26 26		0.0 24.11	1 1.101	O	5.0	10.600 5.000 15.600	150	36.444 0.0			
								0.0962	1.500	Vel =	8.12	
A4			0.0 24.11						37.944	K Factor =	3.91	
H203 to 203A	35 35	4.40	23.44 23.44	1 1.101	N	5.0	0.300 5.000 5.300	150	28.390 0.0			
								0.0911	0.483	Vel =	7.90	
203A to 203B	35 26		0.0 23.44	1 1.101	N	5.0	9.250 5.000 14.250	150	28.873 3.898			
								0.0913	1.301	Vel =	7.90	
203B to 402	26 26		0.0 23.44	1 1.101	O	5.0	2.670 5.000 7.670	150	34.072 0.0			
								0.0913	0.700	Vel =	7.90	
402			0.0 23.44						34.772	K Factor =	3.98	
H202 to 202A	35 35	4.40	23.03 23.03	1 1.101	O	5.0	0.300 5.000 5.300	150	27.400 0.0			
								0.0883	0.468	Vel =	7.76	
202A to 202B	35 26		0.0 23.03	1 1.101	N	5.0	9.250 5.000 14.250	150	27.868 3.898			
								0.0884	1.259	Vel =	7.76	
202B to H402	26 26		0.0 23.03	1 1.101	N	5.0	5.450 5.000 10.450	150	33.025 0.0			
								0.0883	0.923	Vel =	7.76	
H402 to 402	26 26		0.0 23.03	1 1.101			9.330 9.330	150	33.948 0.0			
								0.0883	0.824	Vel =	7.76	
402 to A6	26 26		23.45 46.48	1 1.101	O	5.0	5.900 5.000 10.900	150	34.772 0.0			
								0.3239	3.530	Vel =	15.66	
A6			0.0 46.48						38.302	K Factor =	7.51	
A4 to A5	26 26		24.11 24.11	1.25 1.394			4.100 4.100	150	37.944 0.0			
								0.0302	0.124	Vel =	5.07	
A5 to A6	26 26		0.0 24.11	1.25 1.394			7.650 7.650	150	38.068 0.0			
								0.0306	0.234	Vel =	5.07	

Final Calculations : Hazen-Williams

Page 5
Date

The Village at Discovery - Lot 5 Area #2

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
A6 to A7	26 26		46.47 70.58	1.25 1.394			4.450 4.450	150 0.2222	38.302 0.0 0.989		Vel = 14.84	
A7 to A8	26 26		0.0 70.58	1.25 1.394	N O	6.0 6.0	130.300 12.000 142.300	150 0.2223	39.291 0.0 31.630		Vel = 14.84	
A8 to A9	26 25.500		0.0 70.58	1.25 1.394	N	6.0	4.100 6.000 10.100	150 0.2223	70.921 0.217 2.245		Vel = 14.84	
A9 to A10	25.500 13.850		0.0 70.58	1.25 1.442	E	3.716	12.150 3.716 15.866	120 0.2848	73.383 5.046 4.519		Vel = 13.87	
A10			0.0 70.58						82.948		K Factor = 7.75	
A10 to TOR2	13.850 13.850		70.58 70.58	2 2.157			12.330 12.330	120 0.0401	82.948 0.0 0.494		Vel = 6.20	
TOR2			0.0 70.58						83.442		K Factor = 7.73	
TOR2 to BOR2	13.850 3.500		70.58 70.58	2 2.157	B E Fsp	7.384 6.153 0.0	10.350 13.537 23.887	120 0.0401	83.442 7.483 0.957		** Fixed Loss = 3 Vel = 6.20	
BOR2 to UG	3.500 1		0.0 70.58	4 4.26	E Zca	13.167 0.0	6.500 13.167 19.667	120 0.0014	91.882 8.753 0.028		** Fixed Loss = 7.67 Vel = 1.59	
UG to HOSE	1 0		0.0 70.58	6 6.16	G E T	4.304 20.084 43.037	20.000 67.425 87.425	140 0.0002	100.663 0.433 0.016		Vel = 0.76	
HOSE to TEST	0 0	H100	100.00 170.58	6 6.16			1.000 1.000	140 0.0010	101.112 0.0 0.001		Vel = 1.84	
TEST			0.0 170.58						101.113		K Factor = 16.96	

Job Name : **The Discovery at Discovery - Lot 5**
Address : **1900 NE Discovery Ave. - Lee's summit, Mo**

Date : **8/26/2025**
Sprinkler Contractor : **Goal Fire Protection, LLC**

Area Info : **Area #3 - Unit, 2nd Floor**
Area Design : **Per NFPA-13R, 2016**

Design Criteria :
Gpm for head: **17.0** Psi for head: **12.0**
Total Sprinklers Operating: **3** Sprinkler K Factor: **4.9**
Outside Hose Allowance: **100**

Calculation Summary :

GPM Required : 52.67	PSI Required : 70.42	@ Base of Riser
GPM Required : 152.67	PSI Required : 70.86	@ Connection to City Main

Area Safety Margin: **43.4 PSI 38 %**


Notes :

Water Supply Curve

The Village at Discovery - Lot 5 Area #3

City Water Supply:
C1 - Static Pressure : 115
C2 - Residual Pressure: 70
C2 - Residual Flow : 1501

Demand:
D1 - Elevation : 11.261
D2 - System Flow : 52.669
D2 - System Pressure : 70.869
Hose (Demand) : 100
D3 - System Demand : 152.669
Safety Margin : 43.475



Fittings Used Summary

The Village at Discovery - Lot 5 Area #3

Fitting Legend																					
Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90' Ell	0	4	5	6	7	9	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Branch Tee	0	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zca	Colt C200 Horz Butt	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

The Village at Discovery - Lot 5 Area #3

SUPPLY ANALYSIS

Node at Source	Static Pressure	Residual Pressure	Flow	Available Pressure	Total Demand	Required Pressure
TEST	115.0	70	1501.0	114.344	152.67	70.869

NODE ANALYSIS

Node Tag	Elevation	Node Type	Pressure at Node	Discharge at Node	Notes	
DP01	25.0	4.9	12.04	17.0	0.1	170
EQ01	26.0		11.88			
H301	26.0	4.93	13.46	18.1	K=K @ EQ01	
H302	26.0	4.93	11.88	17.0	K=K @ EQ01	
H303	26.0	4.93	12.68	17.57	K=K @ EQ01	
303	26.0		12.91			
A1	26.0		14.37			
A2	26.0		15.6			
A3	26.0		15.69			
A4	26.0		24.56			
A5	26.0		25.1			
A6	26.0		26.08			
A7	26.0		26.66			
A8	26.0		45.06			
A9	25.5		46.59			
A10	13.85		54.26			
TOR2	13.85		54.55			
BOR2	3.5		62.59			
UG	1.0		70.43			
HOSE	0.0		70.87	100.0		
TEST	0.0		70.87			

Final Calculations : Hazen-Williams

Page 4
Date

The Village at Discovery - Lot 5 Area #3

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
DP01 to EQ01	25 26	4.90	17.00 17.0	1 1.101	O	5.0	0.400 5.000 5.400	150 0.0504	12.037 -0.433 0.272		Vel = 5.73	
EQ01			0.0 17.00						11.876		K Factor = 4.93	
H301 to A1	26 26	4.93	18.10 18.1	1 1.101	O	5.0	10.950 5.000 15.950	150 0.0566	13.465 0.0 0.902		K = K @ EQ01 Vel = 6.10	
A1			0.0 18.10						14.367		K Factor = 4.78	
H302 to H303	26 26	4.93	17.00 17.0	1 1.101			16.000 16.000	150 0.0504	11.876 0.0 0.806		K = K @ EQ01 Vel = 5.73	
H303 to 303	26 26	4.93	17.57 34.57	1 1.101			1.200 1.200	150 0.1867	12.682 0.0 0.224		K = K @ EQ01 Vel = 11.65	
303 to A3	26 26		0.0 34.57	1 1.101	O	5.0	9.850 5.000 14.850	150 0.1873	12.906 0.0 2.781		Vel = 11.65	
A3			0.0 34.57						15.687		K Factor = 8.73	
A1 to A2	26 26		18.10 18.1	1.25 1.394			68.650 68.650	150 0.0179	14.367 0.0 1.231		Vel = 3.80	
A2 to A3	26 26		0.0 18.1	1.25 1.394			4.950 4.950	150 0.0180	15.598 0.0 0.089		Vel = 3.80	
A3 to A4	26 26		34.57 52.67	1.25 1.394			68.650 68.650	150 0.1293	15.687 0.0 8.878		Vel = 11.07	
A4 to A5	26 26		0.0 52.67	1.25 1.394			4.100 4.100	150 0.1293	24.565 0.0 0.530		Vel = 11.07	
A5 to A6	26 26		0.0 52.67	1.25 1.394			7.650 7.650	150 0.1294	25.095 0.0 0.990		Vel = 11.07	
A6 to A7	26 26		0.0 52.67	1.25 1.394			4.450 4.450	150 0.1292	26.085 0.0 0.575		Vel = 11.07	
A7 to A8	26 26		0.0 52.67	1.25 1.394	N O	6.0 6.0	130.300 12.000 142.300	150 0.1293	26.660 0.0 18.403		Vel = 11.07	
A8 to A9	26 25.500		0.0 52.67	1.25 1.394	N	6.0	4.100 6.000 10.100	150 0.1293	45.063 0.217 1.306		Vel = 11.07	
A9 to A10	25.500 13.850		0.0 52.67	1.25 1.442	E	3.716	12.150 3.716 15.866	120 0.1657	46.586 5.046 2.629		Vel = 10.35	

Final Calculations : Hazen-Williams

Page 5
Date

The Village at Discovery - Lot 5 Area #3

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
A10			0.0 52.67						54.261		K Factor = 7.15	
A10 to TOR2	13.850 13.850		52.67 52.67	2 2.157			12.330 12.330	120 0.0233	54.261 0.0 0.287		Vel = 4.62	
TOR2			0.0 52.67						54.548		K Factor = 7.13	
TOR2 to BOR2	13.850 3.500		52.67 52.67	2 2.157	B E Fsp	7.384 6.153 0.0	10.350 13.537 23.887	120 0.0233	54.548 7.483 0.557		** Fixed Loss = 3 Vel = 4.62	
BOR2 to UG	3.500 1		0.0 52.67	4 4.26	E Zca	13.167 0.0	6.500 13.167 19.667	120 0.0008	62.588 7.822 0.016		** Fixed Loss = 6.739 Vel = 1.19	
UG to HOSE	1 0		0.0 52.67	6 6.16	G E T	4.304 20.084 43.037	20.000 67.425 87.425	140 0.0001	70.426 0.433 0.010		Vel = 0.57	
HOSE to TEST	0 0	H100	100.00 152.67	6 6.16			1.000 1.000	140 0	70.869 0.0 0.0		Vel = 1.64	
TEST			0.0 152.67						70.869		K Factor = 18.14	

Job Name : **The Discovery at Discovery - Lot 5**
Address : **190 NE Discovery Ave. - Lee's summit, Mo**

Date : **8/26/2025**
Sprinkler Contractor : **Goal Fire Protection, LLC**

Area Info : **Area #4 - Unit, 2nd Floor**
Area Design : **Per NFPA-13R, 2016**

Design Criteria :
Gpm for head: **17.0** Psi for head: **12.0**
Total Sprinklers Operating: **4** Sprinkler K Factor: **4.9**
Outside Hose Allowance: **100**

Calculation Summary :

GPM Required : 51.65	PSI Required : 56.43	@ Base of Riser
GPM Required : 151.65	PSI Required : 56.84	@ Connection to City Main

Area Safety Margin: **57.4** PSI **50** %


Notes :

Water Supply Curve

The Village at Discovery - Lot 5 Area #3

City Water Supply:
C1 - Static Pressure : 115
C2 - Residual Pressure: 70
C2 - Residual Flow : 1501

Demand:
D1 - Elevation : 11.261
D2 - System Flow : 51.646
D2 - System Pressure : 56.879
Hose (Demand) : 100
D3 - System Demand : 151.646
Safety Margin : 57.473



Fittings Used Summary

The Village at Discovery - Lot 5 Area #3

Fitting Legend																					
Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90' Ell	0	4	5	6	7	9	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Branch Tee	0	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zca	Colt C200 Horz Butt	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

The Village at Discovery - Lot 5 Area #3

SUPPLY ANALYSIS

Node at Source	Static Pressure	Residual Pressure	Flow	Available Pressure	Total Demand	Required Pressure
TEST	115.0	70	1501.0	114.352	151.65	56.879

NODE ANALYSIS

Node Tag	Elevation	Node Type	Pressure at Node	Discharge at Node	Notes	
DP01	25.0	4.9	12.04	17.0	0.1	170
EQ01	26.0		11.88			
H401	26.0	4.93	12.43	17.39	K=K @ EQ01	
H402	26.0	4.93	12.24	17.26	K=K @ EQ01	
402	26.0		12.72			
H403	26.0	4.93	11.88	17.0	K=K @ EQ01	
403	26.0		12.16			
H404	26.0		12.96			
A1	26.0		13.16			
A2	26.0		13.16			
A3	26.0		13.16			
A4	26.0		13.16			
A5	26.0		13.16			
A6	26.0		13.29			
A7	26.0		13.55			
A8	26.0		31.3			
A9	25.5		32.77			
A10	13.85		40.36			
TOR2	13.85		40.63			
BOR2	3.5		48.65			
UG	1.0		56.44			
HOSE	0.0		56.88	100.0		
TEST	0.0		56.88			

Final Calculations : Hazen-Williams

Page 4
Date

The Village at Discovery - Lot 5 Area #3

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
DP01 to EQ01	25 26	4.90	17.00 17.0	1 1.101	O 5.0	0.400 5.000 5.400	150 0.0504	12.037 -0.433 0.272		Vel = 5.73	
EQ01			0.0 17.00					11.876		K Factor = 4.93	
H401 to A5	26 26	4.93	17.39 17.39	1 1.101	O 5.0	8.950 5.000 13.950	150 0.0525	12.425 0.0 0.733		K = K @ EQ01 Vel = 5.86	
A5			0.0 17.39					13.158		K Factor = 4.79	
H402 to 402	26 26	4.93	17.26 17.26	1 1.101		9.330 9.330	150 0.0518	12.238 0.0 0.483		K = K @ EQ01 Vel = 5.82	
402 to A6	26 26		0.0 17.26	1 1.101	O 5.0	5.900 5.000 10.900	150 0.0517	12.721 0.0 0.564		Vel = 5.82	
A6			0.0 17.26					13.285		K Factor = 4.74	
H403 to 403	26 26	4.93	17.00 17.0	1 1.101	O 5.0	0.650 5.000 5.650	150 0.0503	11.876 0.0 0.284		K = K @ EQ01 Vel = 5.73	
403 to H404	26 26		0.0 17.0	1 1.101	N 5.0	10.800 5.000 15.800	150 0.0504	12.160 0.0 0.796		Vel = 5.73	
H404 to A7	26 26		0.0 17.0	1 1.101	N 5.0	6.800 5.000 11.800	150 0.0503	12.956 0.0 0.594		Vel = 5.73	
A7			0.0 17.00					13.550		K Factor = 4.62	
A1 to A2	26 26		0.0 0.0	1.25 1.394		68.650 68.650	150 0	13.158 0.0 0.0		Vel = 0	
A2 to A3	26 26		0.0 0.0	1.25 1.394		4.950 4.950	150 0	13.158 0.0 0.0		Vel = 0	
A3 to A4	26 26		0.0 0.0	1.25 1.394		68.650 68.650	150 0	13.158 0.0 0.0		Vel = 0	
A4 to A5	26 26		0.0 0.0	1.25 1.394		4.100 4.100	150 0	13.158 0.0 0.0		Vel = 0	
A5 to A6	26 26		17.39 17.39	1.25 1.394		7.650 7.650	150 0.0166	13.158 0.0 0.127		Vel = 3.66	
A6 to A7	26 26		17.26 34.65	1.25 1.394		4.450 4.450	150 0.0596	13.285 0.0 0.265		Vel = 7.28	
A7 to A8	26 26		17.00 51.65	1.25 1.394	N O 6.0 6.0	130.300 12.000 142.300	150 0.1247	13.550 0.0 17.748		Vel = 10.86	

Final Calculations : Hazen-Williams

Page 5
Date

The Village at Discovery - Lot 5 Area #3

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
A8 to A9	26 25.500		0.0 51.65	1.25 1.394	N	6.0	4.100 6.000 10.100	150 0.1247	31.298 0.217 1.259		Vel = 10.86	
A9 to A10	25.500 13.850		0.0 51.65	1.25 1.442	E	3.716	12.150 3.716 15.866	120 0.1598	32.774 5.046 2.535		Vel = 10.15	
A10			0.0 51.65						40.355		K Factor = 8.13	
A10 to TOR2	13.850 13.850		51.65 51.65	2 2.157			12.330 12.330	120 0.0225	40.355 0.0 0.277		Vel = 4.53	
TOR2			0.0 51.65						40.632		K Factor = 8.10	
TOR2 to BOR2	13.850 3.500		51.65 51.65	2 2.157	B E Fsp	7.384 6.153 0.0	10.350 13.537 23.887	120 0.0225	40.632 7.483 0.537		* * Fixed Loss = 3 Vel = 4.53	
BOR2 to UG	3.500 1		0.0 51.65	4 4.26	E Zca	13.167 0.0	6.500 13.167 19.667	120 0.0009	48.652 7.768 0.017		* * Fixed Loss = 6.686 Vel = 1.16	
UG to HOSE	1 0		0.0 51.65	6 6.16	G E T	4.304 20.084 43.037	20.000 67.425 87.425	140 0.0001	56.437 0.433 0.009		Vel = 0.56	
HOSE to TEST	0 0	H100	100.00 151.65	6 6.16			1.000 1.000	140 0	56.879 0.0 0.0		Vel = 1.63	
TEST			0.0 151.65						56.879		K Factor = 20.11	

Job Name : **The Discovery at Discovery - Lot 5**
Address : **1900 NE Discovery Ave. - Lee's summit, Mo**

Date : **8/26/2025**
Sprinkler Contractor : **Goal Fire Protection, LLC**

Area Info : **Area #5 - Shell Space**
Area Design : **Per NFPA-13, 2016**
System Type : **Wet System**

Design Criteria :
Density: **0.20** gpm/sq. ft. Operating Area: **1500** sq. ft.
Max. Area Per Sprinkler: **130** Total Sprinklers Operating: **18** Sprinkler K Factor: **5.6**
Outside Hose Allowance: **250**

Calculation Summary :

GPM Required : 459.31	PSI Required : 91.34	@ Base of Riser
GPM Required : 709.31	PSI Required : 92.30	@ Connection to City Main


Area Safety Margin: **11.4** PSI **11** %

Notes :

Water Supply Curve

City Water Supply:
C1 - Static Pressure : 115
C2 - Residual Pressure: 70
C2 - Residual Flow : 1501

Demand:
D1 - Elevation : 5.812
D2 - System Flow : 459.31
D2 - System Pressure : 92.302
Hose (Demand) : 250
D3 - System Demand : 709.31
Safety Margin : 11.454



Fittings Used Summary

The Village at Discovery - Lot 5 -

Page 2
Date

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zca	Colt C200 Horz Butt	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

The Village at Discovery - Lot 5 -

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	115.0	70	1501.0	103.755	709.31	92.302

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>	
SP01	14.42	5.6	18.37	24.0	0.2	120
EQ01	13.42		19.35			
SP02	13.95	5.6	17.46	23.4	0.2	117
EQ02	13.42		18.65			
H501	13.42	5.46	24.09	26.78	K=K @ EQ01	
H502	13.42	5.42	25.34	27.28	K=K @ EQ02	
H503	13.42	5.42	21.35	25.04	K=K @ EQ02	
H504	13.42	5.42	21.5	25.13	K=K @ EQ02	
H505	13.42	5.42	21.94	25.38	K=K @ EQ02	
H506	13.42	5.42	23.01	25.99	K=K @ EQ02	
H507	13.42	5.42	22.02	25.43	K=K @ EQ02	
H508	13.42	5.42	22.21	25.54	K=K @ EQ02	
H509	13.42	5.42	22.87	25.92	K=K @ EQ02	
H510	13.42	5.42	24.03	26.56	K=K @ EQ02	
H511	13.42	5.42	18.65	23.4	K=K @ EQ02	
H512	13.42	5.42	18.78	23.48	K=K @ EQ02	
H513	13.42	5.42	19.1	23.68	K=K @ EQ02	
H514	13.42	5.42	19.91	24.18	K=K @ EQ02	
H515	13.42	5.42	22.92	25.94	K=K @ EQ02	
H516	13.42	5.42	23.11	26.05	K=K @ EQ02	
H517	13.42	5.42	23.8	26.44	K=K @ EQ02	
H518	13.42	5.42	25.0	27.09	K=K @ EQ02	
B1	13.42		27.0			
B2	13.42		27.01			
B3	13.42		27.2			
B4	13.42		27.29			
B5	13.42		28.29			
B6	13.42		40.98			
TOR1	13.42		68.66			
BOR1	3.5		82.03			
BOR2	3.5		82.1			
UG	1.0		91.35			
HOSE	0.0		92.29	250.0		
TEST	0.0		92.3			

Final Calculations : Hazen-Williams

Page 4
Date

The Village at Discovery - Lot 5 -

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
SP01 to EQ01	14.42 13.42	5.60	24.00 24.0	1 1.049	E 2.0	1.000 2.000 3.000	120 0.1823	18.367 0.433 0.547		Vel = 8.91	
EQ01			0.0 24.00					19.347		K Factor = 5.46	
SP02 to EQ02	13.950 13.42	5.60	23.40 23.4	1 1.049	T 5.0	0.500 5.000 5.500	120 0.1740	17.460 0.230 0.957		Vel = 8.69	
EQ02			0.0 23.40					18.647		K Factor = 5.42	
H501 to H502	13.42 13.42	5.46	26.78 26.78	1 1.049		5.610 5.610	120 0.2234	24.089 0.0 1.253		K = K @ EQ01 Vel = 9.94	
H502 to B1	13.42 13.42	5.42	27.28 54.06	1.25 1.38	T 6.0	1.720 6.000 7.720	120 0.2154	25.342 0.0 1.663		K = K @ EQ02 Vel = 11.60	
B1			0.0 54.06					27.005		K Factor = 10.40	
H503 to H504	13.42 13.42	5.42	25.04 25.04	1.5 1.682		7.500 7.500	120 0.0197	21.352 0.0 0.148		K = K @ EQ02 Vel = 3.62	
H504 to H505	13.42 13.42	5.42	25.13 50.17	1.5 1.682		6.120 6.120	120 0.0716	21.500 0.0 0.438		K = K @ EQ02 Vel = 7.24	
H505 to H506	13.42 13.42	5.42	25.38 75.55	1.5 1.682		7.000 7.000	120 0.1526	21.938 0.0 1.068		K = K @ EQ02 Vel = 10.91	
H506 to B2	13.42 13.42	5.42	25.99 101.54	1.5 1.682	T 9.9	5.280 9.900 15.180	120 0.2638	23.006 0.0 4.004		K = K @ EQ02 Vel = 14.66	
B2			0.0 101.54					27.010		K Factor = 19.54	
H507 to H508	13.42 13.42	5.42	25.43 25.43	1.5 1.682		9.000 9.000	120 0.0203	22.025 0.0 0.183		K = K @ EQ02 Vel = 3.67	
H508 to H509	13.42 13.42	5.42	25.54 50.97	1.5 1.682		9.000 9.000	120 0.0737	22.208 0.0 0.663		K = K @ EQ02 Vel = 7.36	
H509 to H510	13.42 13.42	5.42	25.91 76.88	1.5 1.682		7.330 7.330	120 0.1577	22.871 0.0 1.156		K = K @ EQ02 Vel = 11.10	
H510 to B3	13.42 13.42	5.42	26.56 103.44	1.5 1.682	T 9.9	1.720 9.900 11.620	120 0.2729	24.027 0.0 3.171		K = K @ EQ02 Vel = 14.94	
B3			0.0 103.44					27.198		K Factor = 19.83	
H511 to H512	13.42 13.42	5.42	23.40 23.4	1.5 1.682		7.500 7.500	120 0.0175	18.647 0.0 0.131		K = K @ EQ02 Vel = 3.38	

Final Calculations : Hazen-Williams

Page 5
Date

The Village at Discovery - Lot 5 -

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H512 to H513	13.42 13.42	5.42	23.48 46.88	1.5 1.682			5.120 5.120	120 0.0631	18.778 0.0 0.323		K = K @ EQ02	
H513 to H514	13.42 13.42	5.42	23.69 70.57	1.5 1.682			6.000 6.000	120 0.1345	19.101 0.0 0.807		K = K @ EQ02	
H514 to B4	13.42 13.42	5.42	24.17 94.74	1.5 1.682	2E T	9.9 9.9	12.030 19.800 31.830	120 0.2320	19.908 0.0 7.385		K = K @ EQ02	
B4			0.0 94.74						27.293		K Factor = 18.13	
H515 to H516	13.42 13.42	5.42	25.94 25.94	1.5 1.682			9.000 9.000	120 0.0211	22.921 0.0 0.190		K = K @ EQ02	
H516 to H517	13.42 13.42	5.42	26.05 51.99	1.5 1.682			9.000 9.000	120 0.0764	23.111 0.0 0.688		K = K @ EQ02	
H517 to H518	13.42 13.42	5.42	26.44 78.43	1.5 1.682			7.330 7.330	120 0.1636	23.799 0.0 1.199		K = K @ EQ02	
H518 to B5	13.42 13.42	5.42	27.09 105.52	1.5 1.682	T	9.9	1.720 9.900 11.620	120 0.2831	24.998 0.0 3.290		K = K @ EQ02	
B5			0.0 105.52						28.288		K Factor = 19.84	
B1 to B2	13.42 13.42		54.06 54.06	3 3.26			1.420 1.420	120 0.0035	27.005 0.0 0.005		Vel = 2.08	
B2 to B3	13.42 13.42		101.54 155.6	3 3.26			8.160 8.160	120 0.0230	27.010 0.0 0.188		Vel = 5.98	
B3 to B4	13.42 13.42		103.44 259.04	3 3.26			1.590 1.590	120 0.0597	27.198 0.0 0.095		Vel = 9.96	
B4 to B5	13.42 13.42		94.75 353.79	3 3.26			9.410 9.410	120 0.1057	27.293 0.0 0.995		Vel = 13.60	
B5 to B6	13.42 13.42		105.52 459.31	3 3.26			74.000 74.000	120 0.1715	28.288 0.0 12.689		Vel = 17.65	
B6 to TOR1	13.42 13.420		0.0 459.31	3 3.26	2E	18.815	142.610 18.815 161.425	120 0.1715	40.977 0.0 27.679		Vel = 17.65	
TOR1			0.0 459.31						68.656		K Factor = 55.43	
TOR1 to BOR1	13.420 3.500		459.31 459.31	3 3.26	T B E	20.159 13.44 9.408	9.950 43.007 52.957	120 0.1715	68.656 4.296 9.081		Vel = 17.65	

Final Calculations : Hazen-Williams

Page 6
Date

The Village at Discovery - Lot 5 -

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
BOR1 to BOR2	3.500 3.500		0.0 459.31	4 4.26			1.500 1.500	120 0.0460	82.033 0.0 0.069		Vel = 10.34	
BOR2 to UG	3.500 1		0.0 459.31	4 4.26	E Zca	13.167 0.0	6.500 13.167 19.667	120 0.0466	82.102 8.328 0.917		* * Fixed Loss = 7.246 Vel = 10.34	
UG to HOSE	1 0		0.0 459.31	6 6.16	G E T	4.304 20.084 43.037	20.000 67.425 87.425	140 0.0058	91.347 0.433 0.508		Vel = 4.94	
HOSE to TEST	0 0	H250	250.00 709.31	6 6.16			1.000 1.000	140 0.0140	92.288 0.0 0.014		Vel = 7.64	
TEST			0.0 709.31						92.302		K Factor = 73.83	