

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251355
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Tuesday, October 07, 2025

Corrective Action Required:

1	Misc	Soffits approved Approved throughout except at North corridor and IT room/Stairwell walls and both sides of rated storage room walls -Seal gaps at ductwork and label rated assemblies
---	------	---

Comments: