

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

October 07, 2025

Shremshock Architects
7775 Walton Parkway Suite 2540

Permit No: PRCOM20254119
Project Title: LASERAWAY LEE'S SUMMIT - CHANGE OF TENANT / RETAIL AND LASER HAIR REMOVAL
Project Address: 880 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086
Parcel Number: 51700033700000000
Location / Legal Description: SUMMIT FAIR, LOTS 31 & 32-PT LOT 32 DAF: BEG NW COR SE 1/4 SEC-36 TWP-48 RNG-32 TH S 2 DEG 28 MIN 52 SEC E & RAD 139') 74.01' TH S 00 DEG 57 MIN 28 SEC W 65.80' TH S 89 DEG 10 MIN 24 SEC E 231.21' TH S TH SELY ALG LF CURV (RAD 111') 67.86' TO POINT OF REVERSE CURV SELY & SLY ALG RI CURV (RAD 139') 85. W 44.01' TH S 79 DEG 07 MIN 37 SEC E 49.50' TH S 10 DEG 52 MIN 23 SEC W 54.98' TH S 2 DEG 59 MIN 20
Type of Work: CHANGE OF TENANT
Occupancy Group: BUSINESS
Description: LASERAWAY LEE'S SUMMIT - CHANGE OF TENANT / RETAIL AND LASER HAIR REMOVAL - NO ARCHITECTURAL CHANGES - MEP ONLY

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and /or additional information to the application through the online portal. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors

Reviewed By: Joe Frogge

Rejected

1. Lee's Summit Code of Ordinance, Section 7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required: Either a Class A or Class B license is required. Provide the company name of the licensed general contractor and the name, email address & phone number for the on-site contact.

2. Lee's Summit Code of Ordinance, Section 7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors.

DEVELOPMENT SERVICES

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. Lee's Summit Code Of Ordinances 7-137. - Submittal Documents. Construction documents, special inspection and structural observation programs, and other data shall be submitted in two (2) or more sets with each application for a permit. A registered design professional Lee's Summit Code Of Ordinances 7-137. - Submittal Documents. Construction documents, special inspection and structural observation programs, and other data shall be submitted digitally with each application for a permit. A registered design professional licensed by the State of Missouri shall prepare the construction documents. Where special conditions exist, the Building Official is authorized to require additional construction documents to be prepared by a registered design professional licensed by the State of Missouri. I licensed by the State of Missouri shall prepare the construction documents. Where special conditions exist, the Building Official is authorized to require additional construction documents to be prepared by a registered design professional licensed by the State of Missouri.

Action required: Submit plans with engineer's seal/signature.

2. 2018 IBC 1606.2 Design dead load. For purposes of design, the actual weights of materials of construction and fixed service equipment shall be used. In the absence of definite information, values used shall be subject to the approval of the building official.

Action required: Provide engineer's report to verify that existing roof structure will support additional load.

Fire Plan Review

Reviewed By: Craig Hill

Approved

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.