

CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street

Lee's Summit, MO 64063

(816) 969-1200

Fax (816) 969-1201

PLAN REVIEW CONDITIONS

April 03, 2012

DARLAND CONSTRUCTION
4115 SOUTH 133RD ST
OMAHA, NE 68137

Permit No: PRCOM20120634
Project Title: ASPEN ATHLETIC CLUB
Project Address: 178 NW OLDHAM PKWY, LEES SUMMIT, MO 64081
Parcel Number: 62140031600000000
Location: SUMMIT SHOPPING CENTER LOT 1
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: ASSEMBLY FOR INDOOR SPORTING INCL ARENAS, RINKS, COURTS, SWIMMING POOLS
Description: TEMPORARY PRE-SALE AREA

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Michael Weisenborn

Approved

1. 2006 IBC 1011.1 - Where required. Exits and exit access doors shall be marked by an approved exit sign readily visible from any direction of egress travel. Access to exits shall be marked by readily visible exit signs in cases where the exit or the path of egress travel is not immediately visible to the occupants. Exit sign placement shall be such that no point in a corridor is more than 100 feet or the listed viewing distance for the sign, whichever is less, from the nearest visible exit sign.

Action required - To be verified on inspection.

2. 2006 IBC 1006.3 - Illumination emergency power. The power supply for means of egress illumination shall normally be provided by the premises electrical supply. In the event of power supply failure, an emergency electrical system shall automatically illuminate the following areas. 1. Aisles and unenclosed egress stairways in rooms and spaces that require two or more means of egress. 2. Corridors, exit enclosures and exit passageways in building required to have two or more exits. 3. Exterior egress components at other than the level of exit discharge until exit discharge is accomplished for buildings required to have two or more exits. 4. Interior exit discharge elements, as permitted in Section 1024.1, in buildings required to have two or more exits. 5. Exterior landings, as required by Section 1008.1.5, for exit discharge doorways in building required to have two or more exits. The emergency power system shall provide power for a duration of not less than 90 minutes and shall consist of storage batteries, unit

equipment or an on-site generator. The installation of the emergency power system shall be in accordance with Section 2702.

Action required - To be verified on inspection.

Fire Plan Review

Reviewed By: Jim Eden

Pending

- _____ Approved to issue per the listed conditions.
- _____ Do not issue per the listed conditions.
- _____ Approved to construct foundation only per the listed conditions.
- _____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.