

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253204

Address: 213 NW ORCHARD CT, LEES SUMMIT, MO 64063211 NW ORCHARD CT, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Wednesday, October 08, 2025

Corrective Action Required:

1	Miscellaneous Correction	-Protect dryer duct min 2" below plate lines-not done -Joist cut short of beam at powder room (213)-not done **OK to insulate
---	--------------------------	---

Comments: