

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252025
Address: 1432 SE SILO ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, October 09, 2025

Corrective Action Required:

1	Misc	-obtain issued lawn irrigation permit -sod -splash blocks and sump pump discharge to extend 36" from foundation -Outside outlet north side of house, not working
---	------	---

Comments: