

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20252521
Address: 1744 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Shawn Hoffman	Ready for Temp CO	Friday, October 10, 2025

Corrective Action Required:

1	Misc	- lower mirror in bathroom to no higher than 40" from reflecting surface - RTU to be installed and Labeled on unit and electrical panel - Provide an GFCI receptacle within 25' of RTU
---	------	--

Comments: