

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251411

Address: 617 SE BRADFREE ST, LEES SUMMIT, MO 64063619 SE BRADFREE ST, LEES SUMMIT, MO 64063621
SE BRADFREE ST, LEES SUMMIT, MO 64063615 SE BRADFREE ST, LEES SUMMIT, MO
64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Mitchell Schwarz	Failed	Friday, October 10, 2025

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	----------------------------	---

Corrective Action Required:

2	Misc	Erosion control not in compliance -dirt and rock in street -silt fence downed around lot -lot access shall be maintained to allow parking and unloading that prevents tracking of mud and materials onto street
---	------	---

Comments: