

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20243864
Address: 1901 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection	Nick Scott	Partial	Monday, October 13, 2025

Informational:

1 Misc

6-4-25 DP. Perimeter protection needs to be installed with a construction entrance established if accessing from paved road.

10-13-25 NS. Site visited and it appears that ESC is mulch that is around the around the construction site and will fail after first major rain.

Comments: