



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20241886	Date:	October 14, 2025
Project Title:	THE VILLAGE AT DISCOVERY PARK - HOME2 SUITES BY HILTON	Applicant:	
Location:	251 NE ALURA WAY, LEES SUMMIT, MO 64064	RANGER FIRE INC	
Type of Work:		1000 S MAIN ST STE 150	
Occupancy Group:	R-1	GRAPEVINE, TX 76051	
Description:	HOME2 SUITES BY HILTON - THE VILLAGE AT DISCOVERY PARK - NEW HOTEL WITH INDOOR SWIMMING POOL, FOOD AND LAUNDRY SERVICES	Primary:	(817) 410-9070
Construction Type:	Type VA (1 hour)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Craig Hill

Rejected

1. Safety margin on stairwell 1 and 2 are below the limit.

Action Required: Safety Margins need to be 5 or greater.

2. Action Required: Ball drip needed on the riser.

3. Action Required: Test/Drain valve needed on each riser. Show the location of the flow switch on each riser.

Sprinkler Plan Review

Reviewed By: Craig Hill

Released for Construction

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.