

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251423

Address: 616 SE LINDBERG LN, LEES SUMMIT, MO 64063618 SE LINDBERG LN, LEES SUMMIT, MO 64063620
SE LINDBERG LN, LEES SUMMIT, MO 64063614 SE LINDBERG LN, LEES SUMMIT, MO
64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mitchell Schwarz	Failed	Wednesday, October 15, 2025

Corrective Action Required:

1	Misc	-Garage portal frames inspection only. Sheathing breaks must occur in middle 24" of portal leg per design -provide provide design for rated walls extending above roof deck
---	------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: