

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20254089

Address: 206 NW ORCHARD CT, LEES SUMMIT, MO 64063204 NW ORCHARD CT, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Robb Popp	Passed	Wednesday, October 15, 2025

Corrective Action Required:

1	Miscellaneous Correction	-Post address -Complete interior footings -Install Ufer ground -Remove loose soil from footing -Depth of footing to be 36" min
---	-----------------------------	--

Comments: