

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250106
Address: 1817 NE LASHBROOK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Nick Scott	Failed	Thursday, October 16, 2025

Informational:
1 Misc 5-13-25 NS Site visited and it appears that driveway and sidewalk have not been put in and will not be ready for a while.
10/16/25 Tyler S. DW needs to be compacted. Dirt in rock and rock is shallow in areas. Must be a minimum of 4" of aggregate and clean rock. Fail.

Comments: