

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250603
Address: 2524 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Khanh Nguyen	Failed	Friday, October 17, 2025

Corrective Action Required:

1 Misc

Pool bonded:

-Pool shell with 4 bonding jumpers, pool water bonding at skimmer

****corrections:**

-Complete perimeter bonding, water bonding, and bonding jumper to equipment location

Comments: