

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20252521
Address: 1744 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|---------------|----------|--------------------------|
| Occupancy Inspection - Codes Commercial | Shawn Hoffman | Failed | Friday, October 17, 2025 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | Complete corrections for LSFD - RTU to be installed and Labeled on unit and electrical panel - Provide an GFCI receptacle within 25' of RTU |
|---|------|---|

Comments: