

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252500
Address: 2607 SW FIREFLY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Tyler Schreck	Failed	Friday, October 17, 2025

Corrective Action Required:

1	Misc	10/17/25 Tyler S. Dirt and concrete at the curb on both sides of the DW need to be cleaned up. Silt fence also needs to be put back up. If straw waddles are not doing their job, silt fence should be installed. Fail.
---	------	---

Comments: