

Date: 10/15/2025
Company Name: Shremshock
Attention: Waunyai Ward
7775 Walton Parkway Ste 250
New Albany, OH 43054

Project Name: Laseraway Lee's Summit
SMBH Job #: 325-061.012
Re: Structural Supporting CU-1

Waunyai:

It is our understanding that a new condensing unit is being added to the existing roof of the Laseraway tenant fit out project (Lee's Summit Suite H 880 NW Blue Pkwy Lee's Summit, MO 64086). The existing framing consists of open web steel bar joists that span approximately 26' supporting metal deck.

A new 250 pound condensing unit is being added to the roof. The new unit shall be supported by a minimum of two equipment rails that span between joists. The contractor shall verify joist spacings to ensure the rails bear fully on the joist at each end. There is an existing RTU that will remain. See drawing M1.2 (Shremshock) for additional information.

The existing structure is adequate to support the new condensing unit and other code required loads provided the information above is followed.

Sincerely,



Jon Beier, PE, SE, LEED AP
Principal + Vice President
jbeier@smbhinc.com

and



Stephen Metz, PE, LEED AP BD+C
Principal + President
smetz@smbhinc.com

