

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20243864
Address: 1901 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Monday, October 20, 2025

Corrective Action Required:

1	Misc	-Remove all temporary lights and cable from above-ceiling space -120,123, and 124 not ready -Support flexible duct every 5 ft above dog kennels rm 126 -Support ceiling grid every 4 ft
---	------	--

Comments: