

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20251547

Address: 2751 NE DOUGLAS ST, Unit:12, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                     | Inspector: | Outcome: | Date:                    |
|---------------------------------|------------|----------|--------------------------|
| <b>Sewer Service Inspection</b> | Nick Scott | Passed   | Monday, October 20, 2025 |

Informational:

|   |      |                                                                                                                                                                                                                |
|---|------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | 10-20-25 NS Site visited for sewer and it is hooked up to a self isolation sewage tank because they do not have public sewer at this location but will be done in the future with explanation of the air port. |
|---|------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Comments:**