



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120666, Building Permit - Commercial
Address: 871 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|--------------------------|
| Electrical Service Inspection - Commercial | Khanh Nguyen | Failed | Thursday, April 05, 2012 |

Corrective Action Required
1 MISC

-EXPOSE GROUNDING CONNECTION

Comments: