

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20246426
Address: 1460 SE BROADWAY DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	Dustin Agcopra	Partial	Monday, October 20, 2025

Corrective Action Required:

1	Misc	10-20-25 Dustin A, not all of parking lot was ready, proof rolled south side , near the dock and north side of the storm drain. These spots passed and are approved to pour. the rest will need gravel due to it not being thick enough aggregate
---	------	---

Comments: