



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20245940	Date:	October 20, 2025
Project Title:	THE VILLAGE AT DISCOVERY PARK LOT #7	Applicant:	
Location:	1920 NE DISCOVERY AVE, LEES SUMMIT, MO 64064		GOAL FIRE PROTECTION, LLC 20920 147TH ST BASEHOR, KS 66007
Type of Work:			
Occupancy Group:	MIX		
Description:	VILLAGE AT DISCOVERY PARK LOT #7 - NEW 3 STORY APARTMENT BUILDING WITH OPEN AIR PARKING AND COMMERCIAL SPACE FOR FUTURE TENANTS	Primary:	(913) 441-3390
	APARTMENTS - VA PARKING GARAGE - IIA		
Construction Type:	Type IIA (1 hour)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Craig Hill

Rejected

1. Action Required: Add sprinkler heads with heat collector to 3rd floor balconies.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.