



## FIRE DEPARTMENT

Prevention Division  
(816)969-1300

### PLANS REVIEW CONDITIONS

|                  |                                                                                                               |            |                                                                  |
|------------------|---------------------------------------------------------------------------------------------------------------|------------|------------------------------------------------------------------|
| Permit No:       | PRCOM20244782                                                                                                 | Date:      | October 20, 2025                                                 |
| Project Title:   | THE VILLAGE AT DISCOVERY PARK LOT #5                                                                          | Applicant: |                                                                  |
| Location:        | 1900 NE DISCOVERY AVE, LEES SUMMIT, MO 64064                                                                  |            | GOAL FIRE PROTECTION, LLC<br>20920 147TH ST<br>BASEHOR, KS 66007 |
| Type of Work:    |                                                                                                               |            |                                                                  |
| Occupancy Group: | R-2                                                                                                           |            |                                                                  |
| Description:     | VILLAGE AT DISCOVERY PARK LOT #5 - NEW 3 STORY APARTMENT BUILDING WITH LOWER LEVEL LEASABLE COMMERCIAL SPACES | Primary:   | (913) 441-3390                                                   |

1902 NE Discovery Ave has been assigned for the 2nd water meter.

Construction Type: Type VA (1 hour)

Map Page:

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review**

**Reviewed By: Craig Hill**

**Rejected**

1. Action Required: Add sprinkler heads with heat collector to 2nd floor balconies.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**