

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252137
Address: 2233 SW CROWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Tyler Schreck	Partial	Friday, October 10, 2025

Corrective Action Required:

1	Misc	10/10/25 Tyler S. DW is formed and compacted. Approve to pour. 10/21/25 Tyler S. DW is in compliance with city standards. Pass.
---	------	--

Comments: