

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20251907  
Address: 1313 SE RANCLAND ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Ready for Temp CO	Tuesday, October 21, 2025

**Corrective Action Required:**

1	Misc	-provide issued lawn irrigation permit -final grade and sod -Address pending driveway inspection -splash blocks and sump pump discharge to extend 36" from foundation -seal all exterior penetrations
---	------	---

**Comments:**