

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252931
Address: 1218 SE WINDBREAK DR, LEES SUMMIT, MO 640811216 SE WINDBREAK DR, LEES SUMMIT, MO
64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Tuesday, October 21, 2025

Corrective Action Required:

1	Misc	Both sides -remove shower enclosure for drywall at party wall -cspf header must extend to wall corner rear wall -shaft wall must extend to exterior sheathing(see back wall) -missing clips for shaft wall at top of top plate and top of wall -nail all double and triple trusses together to plans 1216 -seal top plate penetrations at primary bath/ closet wall -seal top plate penetration E garage wall 1218
---	------	---

Comments: