



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120668, Building Permit - Commercial
Address: 208 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Khanh Nguyen	Failed	Thursday, April 05, 2012

Corrective Action Required
1 MISC

-PROVIDE 2 RODS SEPARATED AT LEAST 6 FT APART, UNLESS
VERIFICATION OF RESISTANCE TO GROUND OF 25 OHMS OR
LESS IS PROVIDED

Comments: