

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252818

Address: 1212 SE WINDBREAK DR, LEES SUMMIT, MO 640811210 SE WINDBREAK DR, LEES SUMMIT, MO
64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Mitchell Schwarz	Failed	Wednesday, October 22, 2025

Corrective Action Required:

1	Misc	Install clamps correctly for ufer and gas line
---	------	--

Comments: