

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252931

Address: 1218 SE WINDBREAK DR, LEES SUMMIT, MO 640811216 SE WINDBREAK DR, LEES SUMMIT, MO
64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Mitchell Schwarz	Not Ready	Thursday, October 23, 2025

Corrective Action Required:

1	Misc	clamps not installed correctly at ufer and gas line. Not done.
---	------	--

Comments: