

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252931

Address: 1218 SE WINDBREAK DR, LEES SUMMIT, MO 64081
1216 SE WINDBREAK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, October 23, 2025

Corrective Action Required:

1	Misc	Both sides -shaft wall must extend to exterior sheathing (pfh and cspf may not extend into shaft wall) -cspf missing king stud -missing clips for shaft wall at top half of wall and top of wall -nail all double and triple trusses together to plans -top plates intersecting shaft wall frame wall not lapped
		1216
		1218

Comments: