

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252578
Address: 713 SW 15TH CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - R	Dustin Agcopra	Partial	Friday, October 24, 2025

Informational:	
1 Misc	10-24-25 Dustin A, Sanitary wye was installed 9 1 feet down stream from manhole . Contractor will be running tracer wire from connection to sewer stub. Picture uploaded

Comments: