

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20251638
Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection	Tyler Schreck	Partial	Friday, October 24, 2025

Corrective Action Required:

1	Misc	10/24/25 Tyler S. This inspection is for the temporary water service the temporary kitchen. Temporary water line for kitchen and water fire line was installed too shallow at 30".
---	------	--

Comments: