

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253209

Address: 225 NW ORCHARD CT, LEES SUMMIT, MO 64063223 NW ORCHARD CT, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Robb Popp	Failed	Monday, October 27, 2025

Corrective Action Required:

1	DCM1 ESC REQUIRED NO FURTHER INSP	10/27/25 EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE. -Provide gravel filter of min 6" lift of min 3/4" gravel at drive. -Clean silt from street
---	---	--

Comments: