



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20241886	Date:	October 27, 2025
Project Title:	THE VILLAGE AT DISCOVERY PARK - HOME2 SUITES BY HILTON	Applicant:	
Location:	251 NE ALURA WAY, LEES SUMMIT, MO 64064	RANGER FIRE INC	
Type of Work:		1000 S MAIN ST STE 150	
Occupancy Group:	R-1	GRAPEVINE, TX 76051	
Description:	HOME2 SUITES BY HILTON - THE VILLAGE AT DISCOVERY PARK - NEW HOTEL WITH INDOOR SWIMMING POOL, FOOD AND LAUNDRY SERVICES	Primary:	(817) 410-9070
Construction Type:	Type VA (1 hour)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Craig Hill

Released for Construction

Information Only: For hydrostatic test call (816) 969-1300 one business day before needing the test.

Sprinkler Plan Review

Reviewed By: Craig Hill

Rejected

1. Safety margin on stairwell 1 and 2 are below the limit.

Action Required: Safety Margins need to be 5 or greater.

2. Action Required: Ball drip needed on the riser.

3. Action Required: Test/Drain valve needed on each riser. Show the location of the flow switch on each riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.