

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235207
Address: 2931 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Monday, October 27, 2025

Corrective Action Required:

1 Misc **Area at accessible garages/IT closet/Storage not ready

Corrective Action Required:

2 CORRIDORS Lower level, 2->4th floors-OK

1st floor corrections:

- Secure and support all SE cables every 4.5 ft or less; secure wiring within 12" of ceiling boxes
- Mud and tape all GB seams
- Install missing ceiling grids
- Cover ceiling with GB between storage rooms

Comments: