



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120429, Building Permit - Commercial
Address: 1198 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Friday, April 06, 2012

Corrective Action Required
1 MISC

INSTALLATION OF LIGHTED SIGN SUBJECT TO APPROVAL WHEN INSTALLED. PER NEC 600-3: IF INTERNALLY LIGHTED MUST BE UL SHOP-LABELED PER 600.3. INSTALL NO NON-LISTED SIGN.

Corrective Action Required
2 MISC

LIGHTED SIGN FOUND INSTALLED 4/6/2012 DOES NOT BEAR UL LISTING LABEL

Occupancy Inspection - Fire	Joe Dir	Passed	Friday, April 06, 2012
--	---------	--------	------------------------

Corrective Action Required
1 MISC

Emergency lights above the restroom and the rear door need to be repaired to illuminate on DC/ battery power

Comments: