

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20251167  
Address: 627 SE BRADFREE ST, LEES SUMMIT, MO 64063629 SE BRADFREE ST, LEES SUMMIT, MO 64063631  
SE BRADFREE ST, LEES SUMMIT, MO 64063625 SE BRADFREE ST, LEES SUMMIT, MO  
64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Mitchell Schwarz	Failed	Tuesday, October 28, 2025

Corrective Action Required:  
3 Misc

Not a complete inspection, 631 walked through fully only

Throughout

- missing truss bracing on multiple trusses throughout Only
- trusses not fastened together to plans throughout
- protect all NM within 6' of attic accesses
- all pfh walls missing king studs
- gypsum board at separation walls must be able to extend to exterior sheathing

631

-strap top plate where lapped less than 24" front bedroom

629

627

625

**Comments:**