

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20235207  
Address: 2931 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Khanh Nguyen	Failed	Wednesday, October 29, 2025

Corrective Action Required:

1 Misc \*\*Area at accessible garages/IT closet/Storage not ready

Corrective Action Required:

2 CORRIDORS Lower level, 2->4th floors-OK

1st floor corrections:

-Secure and support all SE cables every 4.5 ft or less

\*\*strap SE cables to 2x4 support. Make sure SE cables are secured and supported every 4.5 ft or less

-Cover ceiling with GB between storage rooms

**Comments:**